

CERTIFICATE OF CONFORMANCE

CUSTOMER: CSB Battery

WYLE JOB NO.: 50291

EUT: GP12400, EVX12400, GPL121000, TPL121500 and
MU 1500 Batteries

C OF C NO.: 1

REFERENCES: CSB Battery Purchase Order JEL102703
Wyle Laboratories Quote 543/022519/MW
Telcordia GR-63-CORE, Issue 2
Telcordia GR-1089-CORE, Issue 3
Wyle Laboratories' Quality Assurance Program
Manual Revision 1.

DATE: April 28, 2004

Page: 1 of 1

1.0 TEST PROGRAM

The Equipment Under Test (EUT) was CSB Battery Model Number GP12400, EVX12400, GPL121000, TPL121500 and MU 1500 Batteries. The following tests for the compliance test program performed by Wyle Laboratories for CSB have been completed as of April 28, 2004. Tests and results are as follows:

• Telcordia GR-63-CORE, Issue 2;

- | | |
|---|-----------|
| 1. Section 5.1.1, Non-Operational Temperature and Humidity Test | Compliant |
| 2. Section 5.1.2, Operational Temperature and Humidity Test | Compliant |
| 3. Section 5.1.3, Altitude Test | Compliant |
| 4. Section 5.3.1, Packaged Drop Test | Compliant |
| 5. Section 5.3.2, Unpackaged Drop Test | Compliant |
| 6. Section 5.4.1, Earthquake, Zone 4 Test | Compliant |
| 7. Section 5.4.2, Office Vibration Test | Compliant |
| 8. Section 5.4.3, Transportation Vibration, Curve 1 Test | Compliant |
| 9. Section 5.7.1, Illumination Test | Compliant |

• Telcordia GR-1089-CORE, Issue 3;

- | | |
|---|-----------|
| 1. Section 9.0 Bonding and Grounding Test | Compliant |
|---|-----------|

2.0 RESULTS

The EUT was subjected to GR-63-CORE, Issue 2, and GR-1089-CORE, Issue 3, tests per the aforementioned sections as required by CSB's Purchase Order JEL102703. The EUT met all of the applicable requirements and objectives defined by the above referenced specification. A detailed report describing compliance of the EUT is in preparation and will replace this C of C when issued.

STATE OF ALABAMA
COUNTY OF MADISON

Don Smith, Department Manager, being duly sworn, deposes and says: The information contained in this report is the result of complete and carefully conducted testing and is to the best of his knowledge true and correct in all respects.

Don Smith 4/28/04
SUBSCRIBED and sworn to before me this 28th day of April 2004

Jammy Davis
Notary Public in and for the State of Alabama at large
My Commission expires 22 Oct 2006

Wyle shall have no liability for damages of any kind to person or property, including special or consequential damages, resulting from Wyle's providing the services covered by this report.

PREPARED BY Don B. Davis 4.28.04
Don B. Davis, Project Engineer

APPROVED BY Don Smith 4/28/04
Don Smith, Department Manager

WYLE Q. A. Tom Hamilton 4/28/04
Tom Hamilton, Q.A. Manager

wyle
laboratories

Huntsville, Alabama

(rdh)